



NOTE:

1. All fittings shall be fusion bonded epoxy coated ductile iron to meet or exceed ANSI/AWWA C550 and C116/A21.116 requirements.
2. Select granular will be required between insulation, water main, and obstruction.
3. All bends shall have megalugs or tie rods with blocking in accordance with City Plate No. WAT-05.
4. Copper bonding strap connections shall be used to connect all sections of pipe.
5. All water main bolts shall be core-blue or approved equal.



STANDARD DETAILS
WATER MAIN OFFSET

FARMINGTON, MINNESOTA

Last Revision:
FEB 2017

City Plate No.
WAT-06
2017